



# ICBO Evaluation Service, Inc.

5360 WORKMAN MILL ROAD • WHITTIER, CALIFORNIA 90601-2299

A subsidiary corporation of the International Conference of Building Officials

## EVALUATION REPORT

Copyright © 2000 ICBO Evaluation Service, Inc.

ER-5116

Reissued April 1, 2000

Filing Category: ROOF COVERING AND ROOF DECK CONSTRUCTION—Roof Covering (202)

### WESTERN RED CEDAR ROOF-COVERING SYSTEM

CLARKE GROUP MARKETING, INC.  
33610 EAST BROADWAY AVENUE  
MISSION, BRITISH COLUMBIA V2V 4M4  
CANADA

GREEN RIVER LOG SALES LTD.  
33610 EAST BROADWAY AVENUE  
MISSION, BRITISH COLUMBIA V2V 4M4  
CANADA

GREEN RIVER LOG SALES LTD.,  
HATZIC DIVISION  
34980 LOUGHEED HIGHWAY  
HATZIC, BRITISH COLUMBIA V2V 4J1  
CANADA

#### 1.0 SUBJECT

Western Red Cedar Roof-covering Systems.

#### 2.0 DESCRIPTION

##### 2.1 General:

Western red cedar shakes (non-preservative treated) and shingles are manufactured to comply with UBC Standards 15-3 and 15-4, respectively.

##### 2.2 Installation:

Western red cedar shakes (non-preservative treated) and shingles are installed as prescribed in Table 15-B-2 of the 1997 *Uniform Building Code*™.

#### 2.3 Identification:

Western red cedar shakes (non-preservative treated) (complying with UBC Standard 15-3) and shingles (complying with UBC Standard 15-4) are identified as shown in Figures 1 and 2, respectively. The labels shall include one of the following brand names: Black Hawk, Green River or Scott Cedar.

#### 3.0 EVIDENCE SUBMITTED

Quality control manual and label facsimiles.

#### 4.0 FINDINGS

That the western red cedar shakes (non-preservative treated) and shingles manufactured by the Clarke Group Marketing, Inc., mills listed in this report comply with the 1997 *Uniform Building Code*™, subject to the following conditions:

- 4.1 The products are identified as noted in this report.
- 4.2 The products are manufactured by the listees noted in this report, with inspections by Quality Auditing Institute (AA-635).
- 4.3 The products are installed as stipulated in Section 2.2 of this report.

This evaluation report is subject to re-examination in two years.




FIGURE 1



FIGURE 2

Evaluation reports of ICBO Evaluation Service, Inc., are issued solely to provide information to Class A members of ICBO, utilizing the code upon which the report is based. Evaluation reports are not to be construed as representing aesthetics or any other attributes not specifically addressed nor as an endorsement or recommendation for use of the subject report.

This report is based upon independent tests or other technical data submitted by the applicant. The ICBO Evaluation Service, Inc., technical staff has reviewed the test results and/or other data, but does not possess test facilities to make an independent verification. There is no warranty by ICBO Evaluation Service, Inc., express or implied, as to any "Finding" or other matter in the report or as to any product covered by the report. This disclaimer includes, but is not limited to, merchantability.